DALI GC/GC-A

Datasheet Group Control Module



Module for the control of 2 DALI groups by using conventional momentary switches

> Art. Nr. 24138907 (GC-A) Art. Nr. 24033450 (GC)

subject to change, information provided without guarantee

DALI GC/GC-A Group Control Module


Overview


- Compact control module for 2 DALI groups
- The DALI groups can be selected with a rotary switch on the housing
- Conventional momentary switches can be connected on the inputs
- The DALI GC offers the possibility to address ballasts and add/remove them from groups. The DALI GC-A does not support this feature.
- The DALI GC modules allow multi master operation. Multiple control

modules can be used on the same DALI–line.


- The DALI GC can be easily inserted in the mounting box for the light switch
- The DALI GC must not be connected to the mains. It is supplied directly via the DALI signal line.
- The momentary switches are connected directly to the module (potential free contacts)

type	DALI-GC	DALI GC-A
article number	24033450	24138907
supply	via DALI signal line	
typ. current consumption	6 mA	
input	2 momentary switches single/twin	
output	DALI	
groups	2 from 16/broadcast	
group selection	rotary switch	
addressing mode	Yes (special key sequence)	No
storing temperature	-20°C +75°C	
Operational ambient temperature	-20°C +75°C	
protection class	IP20	
connecting wire cross section	0.75 mm ²	
connecting wire length	250 mm	





connection variants



geometry

Installation

The DALI GC/GC-A is supplied directly via the DALI signal line. A typical value of the current consumption is 6mA. For the supply of the DALI-line a DALI PS can be used. The connection of the DALI-connectors is polarity free and can withstand overvoltage of up to 250Vac.

For group control single or twin momentary switches can be used. Please check the connection diagram for details. The switch inputs are not protected against overvoltage!

Function

Switching of a group is done with a short key press, whereas dimming is performed on long key press actions.

Кеу	Duration	Function
Single Key	40300ms	Max / Off
Uр-Кеу	40300ms	Max / Off
Down-Key	40300ms	Min / Off
		Alternating:
Single Key	>300ms	Dim Up / Down
Uр-Кеу	>300ms	Dim Up
Down-Key	>300ms	Dim Down

The DALI GC/GC-A sends the switching and dimming commands to the predefined groups. Group selection can be done with the rotary switch on the backside of the housing.

rotary switch	group address	
position	Group A	Group B
0	Broadcast	1
1	1	2
2	2	3
3	3	4
4	4	5
5	5	6
6	6	7
7	7	8
8	8	9
9	9	10
А	10	11
В	11	12
С	12	13
D	13	14
E	14	15
F	15	16

Addressing Mode and Group Configuration

The DALI GC supports addressing and grouping, whereas the DALI GC-A does not support this special feature. Please find the details for the programming mode below.

Another way for commissioning is the use of a DALI USB interface and the free configuration tool DALI-Cockpit. With the help of this powerful tool, you can simply set up your DALI-network. However, the DALI GC/GC-A can itself not be accessed by the DALI Cockpit.


Programming Mode

The DALI GC module provides two programming options:

Programming **with** cancelling the existing group settings



and **without** cancelling the existing group settings



Entering Programming Mode:

Press and hold one button for longer than 10 seconds. A beep will confirm. Then you have to release the button for 1 second, again confirmed by a beep. Press the key again. After an additional second 2 beeps will confirm.

Now there is decision for one of the modes.

- → Release button will enter the programming mode without cancelling the active group settings (anytime before having pressed 3 additional seconds)
- Keep button pressed and wait until 3 additional beeps (~3s), releasing the button then will enter the programming mode with cancelling active group settings

After having entered the programming mode all lamps are dimmed to minimum and addressing is started. Each ballast that has been recognized and addressed will be dimmed up to maximum. After having finished addressing the ballast are dimmed to minimum again One ballast will stay at maximum.

The maximum level is an indicator for the selected lamp.

Ballast Selection and Group Assignment:

The selected ballast can be changed by a short button press. With a button press of 3 seconds confirmed by a beep the ballast will be assigned to the group (group selector + switch-input define the active group) if you release the button. Holding the button for additional 3 seconds (overall 6seconds), again indicated with a beep, will remove the selected ballast from the group if you release the key.

Leaving Programming Mode:

Holding the button additional 4 seconds (10 seconds overall) will leave the programming mode (indicated by a 3beep sequence).

DALI Instruction Set

The DALI GC/GC-A operates as control device on the DALI-line. It is based on the standard for Control Gears (IEC 62386-102). In nomral operation the commands in the table below are executed. The DALI GC supports additional commands for addressing and group commissioning..

DALI cmdNr	command	function
0	OFF	OFF
1	UP	Dim Up
2	DOWN	Dim Down
5	RECALL MAX	Maximum
6	RECALL MIN	Minimum
		Goto Minimum if OFF,
	ON AND STEP	otherwise StepUp one
8	UP	Increment ¹

¹ ab V1.3 ist der Befehl ON AND STEP UP implementiert falls der vorhergehende Befehl OFF war. Frühere Versionen senden RECALL MAX.

Additional Information and Equipment

DALI-Cockpit – free configuration tool from Lunatone for DALI systems <u>http://lunatone.at/en/dali-systems/software/</u>

DALI-Manual <u>http://www.dali-</u> ag.org/c/manual_gb.pdf

DALI USB – PC interface for DALI system. The DALI-Cockpit can access DALI components using the DALI USB <u>http://lunatone.at/en/downloads/Lunatone</u> <u>Art24138923_DALI_USB_Datasheet_EN.pdf</u>

DALI PS – power supply for a DALI line http://lunatone.at/en/downloads/Lunatone_ Art24033444 DALI PS Datasheet EN.pdf

Contact

Technical Support: support@lunatone.com

Requests: sales@lunatone.com

www.lunatone.com



