

AT 4044

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME **CB TEST CERTIFICATE** Product **DALI** Component Lunatone Industrielle Elektronik GmbH Name and address of the applicant Paukerwerkstraße 5, 1210 Wien, Austria Name and address of the manufacturer Lunatone Industrielle Elektronik GmbH Paukerwerkstraße 5, 1210 Wien, Austria Lunatone Industrielle Elektronik GmbH Name and address of the factory Paukerwerkstraße 5, 1210 Wien, Austria Note: When more than one factory, please report on page 2 Additional Information on page 2 Ratings and principal characteristics IN: DC 12-24 V; a) 35 mA b) 5 mA; OUT: DALI (voltage according IEC 62386); a) max. 30 mA; b) external power supply required. **D**Lunatone Trademark (if any) Customer's Testing Facility (CTF) Stage used Model / Type Ref. a) 0-10V DALI 30mA, b) 0-10V DALI (1ch, 2ch, 3ch) Additional information (if necessary may also be Built-in 0-10V to DALI converter modules suitable for DIN-Rail reported on page 2) mounting. Additional Information on page 2 A sample of the product was tested and found IEC 61347-1:2015 to be in conformity with IEC 61347-2-11:2001 As shown in the Test Report Ref. No. which TGM-VA EE 37508 SFT, TGM-VA EE 37509 SFT. forms part of this Certificate This CB Test Certificate is issued by the National Certification Body Österreichischer Verband für Elektrotechnik Testing & Certification 2A, 1190 Wien, Austria Kahlenberger Str Digitally signed by W. Martin Email=w.martin@ove.at Date: 2018-09-20 ature: Dipl.-Ing. W. Martin

ZVR: 327279890 | DVR: 1055887